




YORKE PENINSULA COUNCIL

**COMMUNITY WASTEWATER
MANAGEMENT SYSTEMS (CWMS)
INFRASTRUCTURE ASSET
MANAGEMENT PLAN**

MAY 2009

GAYLER PROFESSIONAL ENGINEERING PTY LTD
21 Rundle Street Kent Town SA 5067
Ph: +61 8 8363 7795 Fax: +61 8 8363 9725
Email: rgayler@bigpond.com
Mobile: +61 417 861 952



Typical Activated Sludge Treatment Plant



Gravity Effluent Drains Under Construction

Figs 1 and 2 CWMS Infrastructure

**CWMS
INFRASTRUCTURE ASSET MANAGEMENT PLAN**

TABLE OF CONTENTS

Figs 1 and 2 CWMS Infrastructure	i
SYNOPSIS	4
1. Compliance	4
2. IAMP Outputs	4
3. Methodologies and Data Sources	4
4. Limitations and Exclusions	5
5. General Routine Maintenance and Levels of Service	6
6. Gap Estimation and Expenditure Adjustment Options	8
6.1 General Comment on Gap Estimation	8
6.2 Findings	8
6.3 1-10 and 11-20 Year Gap Estimates	9
6.3.1 1-10 Years	9
6.3.2 11-20 Years	9
7. Testing the Plan	10
8. Applying the Findings of the Plan	11
9. Continuous Improvement Program	11
10. Conclusion	12
APPENDIX 1.1: TABLES AND CHARTS OF CAPITAL RENEWAL	15
1.1 Tables and Charts	15
1.1.1 Aggregated Temporal Capital Renewals	15
1.1.1.1 Long Term Aggregated Renewal Graph	15
1.1.1.2 Treatment Plants Graph	15
1.1.1.3 10 and 20 Year (Aggregated) Graph	15
1.1.1.4 Consensus Data	15
1.1.2 Asset Data	15
1.1.2.1 All Assets and Schemes (Inventory)	15
1.1.2.2 Gravity Pipes Graph	15
1.1.2.3 Gravity Pipes Data	15
1.1.2.4 Rising Mains Graph	15
1.1.2.5 Rising Mains Data	15
1.1.3 Pumps Profile	15
1.1.3.1 Pumps Replacement Graph	15
1.1.3.2 Pumps Profile Data	15
APPENDIX 1.2: SOURCE DOCUMENTS AND DATA	28
1.2 Source Documents and Data	28
1.2.1 Values of CWMS from Council (modified)	28
1.2.2 Example Council Audit (1 of 14 audits) Updated 2009	28



SYNOPSIS

YORKE PENINSULA COUNCIL

CWMS
INFRASTRUCTURE ASSET MANAGEMENT PLAN
MAY 2009

YORKE PENINSULA COUNCIL

CWMS INFRASTRUCTURE ASSET MANAGEMENT PLAN

SYNOPSIS

1. Compliance

This document has been prepared in accordance with the requirements of Sec 122 of the Local Government Act 1999 by GPE Pty Ltd in consultation with Council staff, primarily the Director Engineering Services, the Infrastructure Co-ordinator (Water/Waste water), and the Manager, Finance.

2. IAMPS Outputs

The modelling seeks to identify the current inherent necessary commitment of Capital Renewal Expenditure, in order to retain the existing CWMS Network.

3. Methodologies and Data Sources

Expenditure modelling herein is based on;

- methodologies developed by the IPWEA and Jeff Roorda and Associates; and
- first-principles construction of year-by-year capital renewal expenditure needs from an assessment of estimated aggregated remaining useful lives for each asset group; and
- recognising the imprecise nature of infrastructure lives, costs and performance, a high and low range estimate of future costs have been evaluated. Actual costs are most likely to fall within the limits of these estimates. The mid-range scenario has been incorporated into this report.

The Plan has consciously been developed using readily-available information. Current data across all systems (eg, condition and remaining useful life of each component) have been taken from the CWMS Audits (LGA 2004-2006) and Council's Inventory Sheets for the Yorke Peninsula Council. Ongoing regular updates of the Inventory Sheets are likely to occur, allowing the CWMS Infrastructure Asset Management Plan to be

updated, as required by the Act, within four years from November 2008 (ie, within two years of the election of a new Council).

Where no data existed, figures were either hypothecated from similar Council areas elsewhere in the State, or in discussion with staff.

For the sake of simplicity, aggregated information at the strategic level across the various CWMS asset categories has been used, eg, simple drain lengths and unit rates per metre (not per Class), average relaying costs per metre (not per locality), etc.

It is important that the reader understands the principal purpose of this edition of the IAMP is to identify aggregated asset consumption and gross Capital Renewal Expenditure needs for each asset class at the network level, not at the individual segment level.

In preparing the Plan, extensive input has been provided by experienced Council staff, whose local knowledge has ensured that practical, realistic values have been assigned to the model parameters, including useful lives and unit costs (see Appendix 1.2). Generally, assigned lives are conservative, ie, ***in practice longer lives may be experienced***, depending on the timeliness and appropriateness of system maintenance and repair practices.

A 1-70 year capital renewal expenditure scenario (CRE) has been constructed for all CWMS asset components from first principles and the database, producing histograms of likely renewal years. These were derived from a combination of

1. interpretation of the condition information from the existing database (where these were available); and/or
2. best-guesses of the age or remaining life profiles of asset groups, from local knowledge.

Ongoing monitoring of the field situation and Council's unit costs, and updating of age and condition data will eventually produce more refined outputs.

4. Limitations and Exclusions

The Plan at this stage does not include committed new capital works. ***Generally in the case of CWMS, these will be “donated” assets. If not, they need to be added to proposed expenditure in the years in which they are to occur, since this expenditure is additional to Council’s long-term maintenance and Capital Renewal expenditure.***

It is important to note that any capital expenditure on new assets will add to the ongoing renewal expenditure requirements (but not necessarily in the short term).

Aggregated data give a good approximation of long-term average needs for Capital Renewal expenditure. The plan is NOT intended as a works programming document for any one year at this stage of its development, but it is a gross indicator of the overall capital renewal expenditure needed on CWMS averaged over short and long term periods.

Certain other items have not been costed into the first (simplified) plan, although the level of expenditure in the recent past has included some upgrade component due to replacement of obsolete components with current-standard items. It is unlikely that these have been identified in expenditure records as upgrades.

Items not specifically incorporated into the plan include; -

- New CWMS assets from potential growth, either donated or Council-funded
- Specific works identified in the individual system audits carried out by Council. These have not been costed individually. However, there is an ongoing program of replacement and upgrading of items such as alarms, sludge pumps and switchboards.
Assumptions could be made as to the split between renewal and upgrade portions of recorded expenditure for the aggregated modelling. However, for the sake of simplicity, ***even though expenditure on upgraded equipment is not strictly renewal, it is nevertheless inherent in future replacement items, and is therefore treated as renewal expenditure in the model.*** No other known major deficiencies which would require significant ***new*** capital works are thought to exist; the known deficiencies should all be covered by allocation of funds to continue the ongoing program of replacement/upgrade works implemented by Council over the past two years or so.
- “Disposal” of any “surplus” CWMS assets. No CWMS’s within the actively-replaced network are regarded as superfluous, ie, there are no potential savings in capital renewal expenditure by closing any CWMS.

5. General Routine Maintenance and Levels of Service

For the first edition of the Plan, the fundamental assumption is made that the Level of Service provided by the existing network, as it is presently maintained by Council, is reasonable. It has been noted that Council has

embarked on a program of improved compliance and preventative maintenance expenditure. The Plan assumes that there is room for the level of expenditure on compliance to be maintained at the current level.

Therefore, and with the above proviso, general maintenance practices and levels of expenditure are assumed to be "about right". Unless a detailed condition-based model is populated, and Levels of Service are prescribed, then the best indicator of the appropriateness of maintenance expenditure derives from public perceptions, lack of complaint, manageable level of faults, blockages and call-outs, and the general "feel" of management for the overall health of the network. In Yorke Peninsula's case, the evidence is strong that recent routine maintenance effort and expenditure is appropriate on a network-wide basis for the next few years at least (but not always at an individual component level). However, there may be a case for increased expenditure on line-flushing, pump-station cleanouts and septic tank desludging, based on the number of systems for which flushing has not apparently yet been commenced.

This is not to be confused with obvious major deficiencies in some components; major known deficiencies require **renewal**, not maintenance.

It should be understood that, in the very long term, there is already a large gap between **predicted** capital renewal expenditure need, and historical **actual** capital renewal expenditure.

The main point is to emphasize that an upwards change in standards of maintenance needs to be quantified and disclosed to the community (eg, by inclusion in the Council Budget Papers for information of the community), if such is to occur. The requirement for community consultation is encompassed by provisions of the Local Government Act relating to the annual Budget cycle and Council's Business Plan. Infrastructure Asset Management Plans (required pursuant to Sec 122) constitute part of the financial and business plans of Council, and therefore need to be included in the consultation process.

Council may also wish to inform communities about the potentially higher scrutiny and raised compliance standards (and costs) imposed by the Regulators, and Council's consequential need to exercise due diligence in relation to the various Conditions of Approval and Licencing of their CWMS assets.

6. Gap Estimation and Expenditure Adjustment Options

6.1 General Comment on Gap Estimation

In assigning input values to the various parameters of the model, it is recognised that, with some notable exceptions, much of Yorke Peninsula Council's CWMS network is generally in good condition (supported by the Audit Reports and Inventories).

An assessment has been made of the current state of health and remaining useful lives of the various categories of CWMS asset components. This has allowed an estimation of the future capital renewal expenditure needs to be made, with an approximation of when those works are likely to be needed. Expenditure needs are modelled into the years when they are apparently due (from the current available data), primarily allocated on the basis of assessed end-of-useful life. ***It should be noted that life-estimation is not a precise science, so the results should be regarded as indicative only.***

Recent past expenditure records have then been compared with the long-term average requirements and shorter term requirements. Council's proposed real increases in Service Charges have also been taken into account to show the changing sustainability ratio over the next few years.

6.2 Findings

The appendices contain calculated long-term sustaining levels of necessary Capital Renewal Expenditure for the principal CWMS asset subgroups.

The most significant findings for Yorke Peninsula are;:-

- In the short to medium term, current levels of Capital Renewal Expenditure meet and exceed the inherent requirement, a very sound position (100% sustainable) in which Council finds itself with its CWMS network.
- Over the long term, there is a relatively small estimated gap between predicted capital renewal expenditure need and actual capital renewal expenditure, averaged over the past few years and this year's budgeted expenditure. The gap is roughly 20% of the estimated currently-available CWMS Capex budget of \$381,000 pa.
- There is ample time to review the Plan and costings before any major changes need to be made to current charges and practices

- An important assumption is the ongoing raising of the general residential Service Charges to at least the level indicated in Council's forward financial planning documents (supplied in part to GPE) at approximately \$350 per connection per annum for occupied properties (in 2008 prices).

6.3 1-10 and 11-20 Year Gap Estimates

6.3.1 1-10 Years

Referring to the 1-10 year construct “model” of Appendix 1.1, the modelling shows a requirement for approximately \$124,000pa of Capital Renewal Expenditure compared with current expenditure of up to \$180,000pa.

This does not indicate over expenditure presently, but a concentration or “backlog” of essential renewal and concomitant upgrading of pumps, switchboards, telemetry and control systems.

Therefore there is no “gap” in funding during this period.

6.3.2 11-20 Years

The estimated Capital Renewal Expenditure need in the second ten year period is \$219,000 pa, indicating the need to allocate more of the available CWMS Capex budget to renewal. On the indications from Council's forward Service Charges proposals, the additional funds will be available, thus maintaining the Sustainability Ratio at 100%.

7. Testing the Plan

The mathematical modelling and spreadsheets are designed to allow multiple trials of parameter values to be tested.

It is particularly important to test the results by substituting different cost and life figures if and when they become available.

The findings of the first edition of the CWMS IAMP can be used to; -

- Identify items for careful checking, debate and adoption of unit cost figures and useful lives
- Provide input to Council's long term financial and business plans, on the basis of the CWMS indicators of renewal funding requirements
- Form the basis for informing communities about the cost of mandatory Compliance Levels of Service to be maintained or raised (eg the two primary Regulators, namely, the EPA and Department of Health)
- Form the basis against which to assess Council's capacity to invest in new capital works and upgrades, or to accept ownership of additional CWMS infrastructure from new land developments, by adding their life-cycle costs to the known existing assets total life-cycle cost
- Demonstrate to Council the fluctuating nature of annual asset preservation and renewal costs
- For annual budget purposes, to indicate the total amounts required to fully fund renewal works for the whole CWMS Asset. ***Within those allocations, Council managers should have the authority and responsibility to determine actual priorities across the whole spectrum of individual asset components, based on current inspection and other agreed determinants***
- Identify any gaps, shortcomings or need for updating of data (condition, risk factors, redundancy, statutory compliance etc)
- Identify any gaps or needs in systems (eg, GIS and Asset Register systems, corporate accounting and reporting systems, job cost recording systems including depot timesheets and job numbering)
- Form the basis for future (expanded) revisions of the IAMP

- ***This Plan should not be used as a tool for determining actual works programs, which require much greater detailed evaluation of current asset attribute data on an individual basis***

8. Applying the Findings of the Plan

The findings of the first edition of this CWMS Infrastructure Asset Management Plan should be applied with caution. As stated, the completeness, currency and accuracy of the multitude of data variables lie within broad confidence levels only. The results should be used as gross indicators of the sustainability of the asset overall, in the knowledge of the intent to pursue a continuous program of improvements to the Plan in future updates.

Council has recently invested in staff resources to commence data capture on the extent, condition and costs of their CWMS's, and intends to maintain the quality and currency of its database. The individual system audits are a good example of the commitment of Council to improved information and records for CWMS.

Ongoing improvements to the financial modelling of capital renewal requirements will come about through gradual completion of detailed attribute data of the myriad components of the network, careful monitoring of actual unit costs and achieved useful lives. Changes to these inputs have a direct effect on the annual asset consumption figures.

Adding any proposed new capital works expenditure or "big ticket" upgrade works into the Plan will ensure that sustainability is addressed at the time of making decisions on whether to proceed with such works, or not.

Should Council wish to change the Level of Service provided by any component of its CWMS Network (eg, compliance or increased maintenance effort), the financial information in the Plan should be modified to reflect the potential costs of so-doing.

9. Continuous Improvement Program

A step-wise Improvement Schedule to the first Plan would be as follows:-

1. careful checking, debate and adoption of unit cost figures and useful lives in this edition
2. completion of full records of system records (drawings, quantities, condition etc) in a formal user-friendly database

3. full accounting for future Capital Renewal expenditure and sourcing of funds for same (grants, connection and headworks fees, service charges, rebates and exemptions)
4. costing and inclusion of proposed upgrade capital works (where these are not covered by normal budget allocations)
5. ongoing in-house review of unit cost rates and achieved useful lives
6. Costing of mandatory Compliance Levels of Service and/or required once-off improvement works
7. visual examination of gravity drains for better life estimation (CCTV)
8. refining the modelling into a greater number of components, valuation of components by technical class (eg, Rising Main Pressure classes). This should only be undertaken if the approximate figures and coarser component aggregation prove to be insufficiently accurate for gross financial planning purposes

Suggested Program:	Item 1	Immediate and ongoing
	Item 2	Years 1-5
	Item 3	Years 3-4
	Item 4	Years 2
	Item 5	Ongoing
	Item 6	Years 2
	Item 7	Long term
	Item 8	Ongoing, if warranted

10. Conclusion

The principal objective of Council's first CWMS Infrastructure Asset Management Plan is to model and bring to account an estimate of the inherent Capital Renewal Expenditure requirement embodied in the *existing* CWMS network.

Individual asset groups have been modelled as well as the combined Total CWMS Assets. Indicative Capital Renewal Expenditure needs have been charted for each asset subgroup over their estimated life cycle periods.

A substantial gap between necessary and actual Capital Renewal Expenditure has been identified. **The results should be regarded as indicative only**, i.e., the funding “gap” should not be regarded as an accounting figure, but as a guide to Council and Managers on the overall expenditure needs on the CWMS Assets. Short, medium and long term scenarios have been modelled.

In the period to 40 years, the Sustainability Ratios look very sound. Estimated Capital Renewal Expenditure requirements appear to be fully coverable within Council’s current CWMS Capex capacity. That is to say, the sustainability ratio is 100%.

In the long term (beyond 40 years) the ratio drops to around 82% (but only 40% at the current rate of specific renewal expenditure. However the capacity is there to achieve 82% without increasing Capex funds).

The models can be re-run easily (and need to be) if and when more precise data become available, or to check the impact of different assumptions about the life and unit costs pertaining to groups and subgroups of the CWMS Assets.

Future editions of the Plan will benefit from implementation of the recommended Continuous Improvement Program, particularly from more comprehensive attribute, condition and unit cost data.



APPENDIX 1.1

YORKE PENINSULA COUNCIL

CWMS
INFRASTRUCTURE ASSET MANAGEMENT PLAN
MAY 2009



YORKE PENINSULA COUNCIL
CWMS
INFRASTRUCTURE ASSET MANAGEMENT PLAN


APPENDIX 1.1: Tables and Charts of Capital Renewal

1.1 Tables and Charts

- 1.1.1 Aggregated Temporal Capital Renewals**
 - 1.1.1.1 Long Term Aggregated Renewal Graph**
 - 1.1.1.2 Treatment Plants Graph**
 - 1.1.1.3 10 and 20 Year (Aggregated) Graph**
 - 1.1.1.4 Consensus Data**
- 1.1.2 Asset Data**
 - 1.1.2.1 All Assets and Schemes (Inventory)**
 - 1.1.2.2 Gravity Pipes Graph**
 - 1.1.2.3 Gravity Pipes Data**
 - 1.1.2.4 Rising Mains Graph**
 - 1.1.2.5 Rising Mains Data**
- 1.1.3 Pumps Profile**
 - 1.1.3.1 Pumps Replacement Graph**
 - 1.1.3.2 Pumps Profile Data**



Aggregated Long Term Replacement




1.1.1.1

Long Term Aggregated Capital Renewal Expenditure Requirements




Treatment Plant Renewals



1.1.1.2 Treatment Plants Capital Renewal Expenditure Requirements



Funding Picture by Period



1.1.1.3 10, 20 Year & Long Term Aggregated Capital Renewal Expenditure Needs vs Current Expenditure



CWMS Gross Weighted Average Capital Renewal Requirement

Gross Weighted Average Capital Renewal Requirement

NOTE: A 10% change in useful lives will cause a range of Capital Renewal Requirement of +/- 464,320.5 pa

Current Estimated Operating and Maintenance	484000	Extra Compliance Costs: nominal allowance
Estimated Compliance Expenditure Gap	20000	
Estimated Total Income Year 1 modified**	705000	Modified to account for proposed Service Charge increases
Estimated Total Income Year 2 modified***	700000	
Estimated Total Income Year 3 modified****	690000	

1.1.1.4 Consensus Capital Renewal Expenditure Need - Data

****NOTE:** Excludes loan repayments of \$200,000 pa

****NOTE:** Excludes loan repayments of \$200,000 pa




All Assets and Schemes Inventory

30



Gravity Replacements



1.1.2.2 Gravity Pipe Capital Renewal Expenditure Needs by Diameter




Due	Age	Drains PVC	100 150 2502	225 100 100	GRAVITY DRAINS 70 YEAR LIFE							
					General	26	44	44	2400	Year Due	Gravity	
56	14				66-70	1880	150	225	2	<65	75-80	90-110
70	70	70	70	70	61-65	9000	2740	3014	740	740	117	>110
61	9	8750	650		56-60	2797	1362					
61	9				51-55							
61	9				46-50							
61	9				41-45	15816	2502	100				
59	11				36-40							
59	11				31-35							
59	11				26-30							
60	10	397	548	814	1117	21-25						
60	10				16-20							
60	10				11-15							
60	10				6-10							
68	2				1-5							
62	8											
62	8											
63	7	250	1086		1-5		0	0	0			
63	7				6-10		0	0	0			
64	6				11-15		0	0	0			
66	4	1380	522	740	16-20		2000	500	0	102000		
61	9		211		21-25		2000	500	0			
67	3	500	2529	2	26-30		2000	500	0	262000		
67	3				31-35		2000	574	0		220160	
68	2				36-40		2760	0	0			
68	2				41-45		15816	2502	100	1534480		
62	8				46-50		0	0	0			
63	7	29493	9618	959	51-55		0	0	0		161227	
					56-60		2797	1362	117			
					61-65		9000	3014	740			
					66-70		1880	2740	2	1438260		

1.1.2.3 Gravity Pipe Capital Renewal Expenditure Need - Data



Rising Main Replacement



1.1.2.4 Rising Mains Capital Renewal Expenditure Needs by Diameter



RISING MAIN 50 YEAR LIFE

Age	40-63 mm	Cond'n	75-80mm	Cond'n	100mm	Cond'n	150mm	Cond'n	Due	<60	75-80	90-110	>110	1-5	6-10	<60	75-80	90-110	>110
26	366	2								24	366			2980	1	16	2980	11-15	13500
	488	1								16	488					12	1733	2593	
44	150	1	1733	0						4	150					4	16-20	888	1733
150	0									2	150					2	21-25	366	407865
14	300	2								36	300					36	26-30		16470
600	2									36	600					36	31-35		
9	300	2								41	300					41	36-40	2510	
9	180	2								41	180					41	41-45	1205	
9	130	2								41	130					41	46-50	3400	
9	700	0								15	700					15	46-50	3020	407865
9	160	0								15	160					15	1150		
9	400	1								41						41	1100		
11	670	2								39						39	1150		
11	940	2								39	670					39	405		
10	800	2								40	940					40	940		
10	10									40						40	800		
10	10									40						40			
2	460	2								42	460					42	460		
8	1690	2								42						42	1690		
7	1690	2								43						43			
7	7									43						43			
6	4	1900	2							44						44			
9	9									46	1900					46	450		
3	3	400	2							41						41	1100		
2	2	170	2							47	400					47	2200		
2	2	550	2							48	170					48	550		
8	8	200	2							42	200					42	200		
7	7									43						43	610		
										20						20	400		


1.1.2.5

Rising Mains Capital Renewal Expenditure Need - Data

2200



Pump Replacements



1.1.3.1 Pumps Replacement Schedule – Numbers per Year



Age	Raw No	Year Due	Pumps	Number
1	0.066667	15	11	3
2	0.133333	14	14	2
3	0.2	13	29	1
4	0.266667	12	29	
5	0.333333	11	4	
6	0.4	10	6	
7	0.466667	9	6	
8	0.533333	8	4	
9	0.6	7	8	
10	0.666667	6	2	
11	0.733333	5	2	
12	0.8	4	2	
13	0.866667	3	2	
14	0.933333	2	2	
15	1	1	2	
16	1.066667	15	0	
17	1.133333	14	0	
18	1.2	13	2	
19	1.266667	12	2	
20	1.333333	11	2	
21	1.4	10	2	
22	1.466667	9	2	
23	1.533333	8	2	
24	1.6	7	2	
25	1.666667	6	2	
26	1.733333	5	2	
27	1.8	4	2	
28	1.866667	3	2	
29	1.933333	2	2	
30		1	2	
31	2.066667	1	1	
32	2.133333	2	1	
33	2.2	3	1	
34	2.266667	4	1	
35	2.333333	5	1	
36	2.4	6	1	
37	2.466667	7	1	
38	2.533333	8	1	
39	2.6	9	1	
40	2.666667	10	1	
41	2.733333	11	1	
42	2.8	12	1	
43	2.866667	13	1	
44	2.933333	14	1	

1.1.3.2 Pump Profile Data



APPENDIX 1.2

YORKE PENINSULA COUNCIL

CWMS
INFRASTRUCTURE ASSET MANAGEMENT PLAN
MAY 2009



YORKE PENINSULA COUNCIL

CWMS

INFRASTRUCTURE ASSET MANAGEMENT PLAN

APPENDIX 1.2: Source Documents and Data

1.2 Source Documents and Data

- 1.2.1 Values of CWMS from Council (modified)**
- 1.2.2 Example Council Audit (1 of 14 audits) Updated 2009**



Scheme	Current Replacement Value	Depreciation 2007/08	Written Down Value
Ardrossan / Tiddy Widdy	\$ 4,613,666.00	\$ 58,145.00	\$ 2,360,718.00
Maitland	\$ 2,465,288.00	\$ 33,117.00	\$ 756,980.00
Black Point	\$ 769,639.00	\$ 13,077.00	\$ 485,170.00
Yorketown	\$ 2,858,757.00	\$ 48,242.00	\$ 2,099,912.00
Sultana Point			
Rogues Point			
Bluff Beach	\$ 21,871.00	\$ 364.00	\$ 20,777.00
Hardwicke Bay	\$ 287,467.00	\$ 5,133.00	\$ 277,201.00
Chinaman Wells			
Port Victoria	\$ 249,537.00	\$ 5,096.00	\$ 236,456.00
Port Vincent Marina	\$ 1,479,735.00	\$ 17,275.00	\$ 836,312.00
Port Vincent Rise			
Stansbury	\$ 1,144,445.00	\$ 19,074.00	\$ 1,365,732.00
Foul Bay			
Point Turton	\$ 13,890,405.00		

Add 22% to give 09 costs and 6 private schemes => approximately \$19.6m

\$ 16,946,294.10
\$ 2,700,000.00
\$ 19,646,294.10

1.2.1 Values of CWMS from Council (adjusted to 2009)



1.2.2 Example Council Audit – Maitland

District Council of Yorke Peninsula Community Wastewater management schemes

Gravity Drains

Township-Maitland Date 19/3/2007

Reviewed 12/5/2009

	Details	Comments
Total length	13,243 meters	Vitruce Clay- Earthen ware
Age of system	Installed 1965	42 yrs 44 yrs
Design life	50 years	life remaining -8 years
Materials	Earthen ware	2574 mtr of 150mm 10669 mtr of 100mm
Replacement costs	\$860,000	As at 2005 pricing
Manholes	Very large and heavy needs two people to lift lid, this process also lets dirt and rubble enter drain system	Consideration needed to replace all lids so only a small manhole needs to be lifted to get access to drain- new access chambers lids are currently being installed
Summary	Maitland's gravity drain system is currently in poor condition. Ongoing breakages and blockages are a continual problem for the councils engineering department. Trail work with high pressure drain cleaning and octv inspections Programmed for March 07 will better assess condition of drains Strong diesel smell coming from southern side of town to be investigated Continue 4 yearly desludging of septic tanks	



Pump Stations

Number of stations - 2

Station number-1	Details	Comments
Location	South Terrace	
Type/Manufacturer	Mono pumps	Single pump station
Installed	1965	
Alarm/Telemetry	Red flashing light on shed	Rely on public to inform council of any faults-no telemetry
Switchboard	Very basic	Etsa meter and circuit breakers moved mid 2006 off stoobie pole and installed into stand alone cabinet
Tanks	Average	
Lids	Concrete	
Signage	None	Authorized personal and confined space signage needed
Vents	None	Needs consideration if pump station upgraded
Sheds	Very poor	Access to pumps difficult
Pipe work	Average	
Valving	Average	
Surrounds	Average	
Summary	The current mono pumps are due for replacement, twin submersible pumps and new switchboard to be installed in coming years- no upgrade as of yet	



		Details	Comments
Station number-2	Clinton road		On footpath
Location	Mono pumps –Itt Flygt		Single pump station-Twin pump station
Type/Manufacturer	1965		11/2006
Installed			
Alarm/Telemetry	Red flashing light on top of shed New Cell visor sms system	Rely on public to inform council of any faults -no telemetry- installed	
Switchboard	Very basic-new two control switch board installed	Etsa meter and circuit breakers mounted on stobie pole-etsa meter mover into top of new board	
Tanks	Average		
Lids	Concrete	one new aluminium hinged lid installed	
Signage	None	Authorized personal and confirmed space signage needed	
Vents	None	Needs to be considered when station upgraded	
Sheds	Very poor no shed needed	Difficult to access pump	
Pipe work	Average replaced	Flush point installed	
Valving	Average	Due for replacement- replaced	
Surrounds	Average	Footpath needs building up and some vegetation removed	
Summary	This pump station programmed for upgrade in early 2007, Itt Flygt pumps are to be installed along with new switchboard and etsa meter moved. Costing \$18,000-completed		



Rising mains

	Details	Comments
Pump station number-1		
Location	West along South Terrace right into Eldon street, into pit in Howard street	
Lengths	150 meters	Estimate
Age	1965 -42yrs	
Material	40mm pvc	Unsure of class
Flushing points	none	Can be flushed at end of line
Summary	Only a small rising main, no history of any faults, breakages or blockages. Possible future cleaning maybe required and flushing point installed at pump station when upgraded	
Pump station number-2		
Location	Travels due west from pump station along adjoining properties fence line to Burlington street to pit on western footpath	
Lengths	150meters	Estimated
Age	1965 -42 yrs	
Material	40mm pvc	Unsure of class
Flushing points	none	Can be flushed at end of line
Summary	Only small rising main, there has been blockages in the past ,flushing point at pump station will need to be considered when station upgraded- flush point installed	



Treatment plants

	Details	Comments
Manufacturer	Aeroflow	
Year	1994	
Age	13 years 15	
Capacity	451 connections-@1200 EP people or around 190,000 litres per day	Currently around 125,000 litres per day consistently flows through this plant Around an additional 65,000 litres is aloud before any upgrading size of plant needed
Summary	Plant size is more than adequate for Maitland current population, future extra connections would be aloud [up to 65,000ltrs or around 100 connections] If and or when the remainder of Maitland is considered Department of health approvals to be located	

Intermittent aeration tank

	Details/condition	Comments
Concrete tank	Good –Diameter 9.1 metres Depth 2.2 metres Water height 1.7metres 160,000 litres	No signs of cracking some slight pitting of internal wall near aerator
Aerator -Number	1	
-Size	750 kilowatt 415 volt	



-Condition	Average
Summary	Generally in good condition, ongoing aerator maintenance essential

Aeration Anoxic Tank

	Details	Comments
Concrete tank	Good – Diameter 9.1 metre Depth 2.2 metre Water height 1.7 metres 160,000 litres	No signs of cracking some slight pitting of internal wall near aerator
Aerator-Number	1	
-Size	750 kilowatt 415 volt	
-Condition	Average	Bearings slightly noisy, due for replacement-replaced
Return activated sludge pump [ras]- Size	300	
-Condition	Average	
-Pipe work	Average-pvc	Some cracking around tank entry
Waste activated sludge pump [was]-Size	Itt Flygt	
-Condition	Good	
-Pipe work	Good	
Decant arms-condition	Good	
Solenoid Valves-brand	Aero float -twin Goyen controls	24 volt model 20b12
-Condition	Good	



Water height measure-Type	Float type-upgraded to Hydro static	Possible upgrade to new technology needs considering
-Condition	Some signs of weathering	Due for replacement
Summary	In generally good condition ,ongoing maintenance needed	

Decant tanks

Chlorine contact tanks	Details	Comments
-size	Diameter 3.5 metres Depth 2.6 metres Overflow height 2.0 metres	3 tanks in total
-Condition	Good	
-Security	Good	Confined space signage needed
-Signage	Good	Adequate - upgraded to hydro static
Water height measuring	3 level floats ,1 alarm float	New pumps installed late 2005
Decant pumps	2 grundfos dep10 pumps	Replaced when new pumps installed
Pipe work	80mm Hdpe to top of first dam Pvc around top of dam to upper dam	Two small leaks in pvc need repairing -repaired
Valving	Good	Replaced when new pumps installed
Overflow	Good	Any overflow of plant is piped to an old evaporation pond for containment
Summary	Decant tank capacity and condition is very good ,upgrading of pumps, valving and pipe work in 2005 has resolved several faults- tanks cleaned on a regular bases	tanks cleaned



Waste Activated Sludge Tank

	Details	Comments
Size	160,000 litres	Desludged regularly
Tank condition	Good	
Roof condition	Poor	Rusting badly, will be due for replacement in the near future
Pipe work	Good	
Summary	In generally good condition, when new roofing installed tank will be improved	

Switchboard

	Details	Comments
Timers	Mechanical	Some controls very hard to access
Switches	ok	extra switches needed for chlorine pump
Electrical safety switch	Present	For general power outlet only
Lights/test buttons	ok	Alarm test button needed
Summary	A very basic switchboard with very little operator control available A general upgrade to a plc unit needed so more adjustment available during peak periods and also power savings during night time can be obtained - new switchboard installed 09/08	



Dialler/Telemetry

		Details	Comments
Brand	Nidac landline		Very basic
Age	1994 -14 years		
Condition	Poor		This brand being phased out
Summary	Unit has been disconnected because landline is damaged and the cost saving available with a gsm unit has determined that a new dialler is needed, currently on order- upgraded with new switchboard		

Flow meters

		Details	Comments
Brand	ABB Mag meter		New
Age	October 2006		
Condition	Very good		
Annual flow	45,625,000 litres		Estimated
Average daily flow	125,000 litres per day		Summer 06/07
Summary		Very good tool in the day to day running of the plant also will be helpful in determining as to whether Maitland's gravity drain network has much infiltration during winter- no increase in flow for the last two years	



Filtration

		Details	Comments
Brand	None		
Age	None		
Condition	-		
Summary	A filtration plant could be installed at this treatment plant but the cost would be large, the current treatment process is producing good quality water so there is no current need for any filtration		

Chlorine Dosing

		Details	Comments
Brand	Grundfos		Dms 4-7 b 3 litres /hour
Age	2007		-
Condition	Good		-
Pipe work	Average, need better quality in future		New 2007
Holding Tank	1800 litres		Good new 2007
Bunting	1200 litres emergency storage		Good new 2007
Signage	Some extra signage needed		Protective clothing Hazardous substances
Emergency Shower	None		-
Storage	Separate area outside main shed		Good, well ventilated
Msds sheets	Present and available		



Summary	Chlorine dosing system reinstated in 2007 after many years disconnected Preforming well, consideration needed for the future purchasing of more signage and an emergency shower	
----------------	---	--

Storage sheds

	Details	Comments
Security	Good	
Condition	Good	
Fire extinguisher	Present and inspection up to date	
Summary	Is in good condition and is adequate for plant	

Water Supply

	Details	Comments
Supply	Main pressure	
Pressure	Good	
Summary	Very adequate	

Compound

	Details	Comments
Fencing	Good	
Gates	Good	



Security	Good
Signage	None
Summary	In generally good condition

Treated water reuse

	Details	Comments
Description	Treated water is pumped into either of two storage dams where it can be mixed with stormwater	Works well, all water is used by either golf course or bowls club
Condition	Good	
Storage	Two large dams	High evaporation levels
Irrigation system	Maintained by golf club	
Transfer pump	Second hand centrifugal pump electrically controlled from treatment plant shed , transfers water from lower dam to top dam	Pump and pipe work due for upgrade also needs to be stored in its own [vandal proof] shed on side of dam - new shed erected
Summary	If extra water becomes available consideration should be given to supplying other areas of town possibly town oval, nature strips, or road building.	Department of health approvals for storage dams needs to be investigated, Have they already been approved?



Water Quality

	Details	Comments
Overall	Poor-has improved and generally very good	Needs to be improved
Treatment plant	Has improved with the reinstallation of the chlorine dosing system Last two samples E-coli –one below and one above desired levels Suspended solids –both below desired levels Bod –one below and one above desired levels	Hopefully will continue to improve with closer monitoring Desired levels as set by department of health E-coli 100/100ml Suspended solids 30mg/l Bod 20mg/l
Irrigation	Last two samples E-coli both slightly <u>above</u> desired levels Suspended solids-one <u>above</u> one below desired levels Bod –both below desired levels	Hopefully will continue to improve with closer monitoring
Summary	Continue monitoring both plant results and water sample results to see if they improve, some small improvement at the plant should help results- no longer a concern	



Occupational Health and Safety

Any issues that have became apparent during audit

1. Improved signage needed-**some new signage installed**
2. Emergency shower facility needed at treatment plant in case of chemical spillage
3. Manual handling issues with lifting manhole covers-**being resolved with new lids**
4. Continue using personal protective equipment when handling waste water and chlorine
5. Several areas classified as confined spaces

Overall scheme review and priorities

1. Develop annual gravity drain cleaning and inspection program to eventually clean all drains in Maitland and access problem areas that may need replacement-a **large area of Maitland's drains have been cleaned over the last two years -some drains several times over**
2. Investigate to see if both treatment plant and storage dams have department of health approval's
3. Upgrade both pump stations to include two submersible pumps at both location ,new switchboard, telemetry and flushing points-**one station done**
4. Upgrade switchboard ,water level indicator and telemetry at treatment plant-**done**
5. Replace dam pump, pipe work and house in shed -**new shed erected, dam pump overhauled**
6. Replace all town manhole covers with easier to handle covers, so it's only a one man operation to check drain-currently being **done**
7. Investigate strong diesel smell coming from southern side of town
8. Replacement of waste activated sludge [was] tank roof-**on order**